

SYSTEM DATA

- WELL SITE No. 1**
- 1 - WELL AT 1/2 DPM, 1500 FL, Deep, 1" Casing
 - 1 - 10000 GALLON ELEVATED STORAGE TANK
 - 1000 GPM SERVICE PUMPS 3-200 GPM
 - 2" FLOW METER FOR WELL No. 1 & 2
 - 4" FLOW METER FOR WELL No. 2 AT GROUND STORAGE TANK
 - CHLORINATION FACILITIES FOR WELLS 1 AND 2
- WELL SITE No. 2**
- 1 - WELL AT 1/2 DPM, 1500 FL, Deep, 1" Casing
 - 1 - 10000 GALLON ELEVATED STORAGE TANK (MULTIPLE)
 - MARTIN CONTROL CENTER
 - CHLORINATION FACILITIES AT WELL SITE No. 1
 - FLOW METER LOCATED AT WELL SITE No. 1
- WELL SITE No. 3**
- 1 - WELL AT 1/2 DPM, 1500 FL, Deep, 1" Casing
 - 1 - 10000 GALLON ELEVATED STORAGE TANK (MULTIPLE)
 - CHLORINATION FACILITIES
 - 4" DENBUR TURBO-METER IN VAULT W/ BY-PASS
- WELL SITE No. 4**
- 1 - WELL AT 1/2 DPM, 1500 FL, Deep, 1" Casing
 - 1 - 10000 GALLON ELEVATED STORAGE TANK (MULTIPLE)
 - CHLORINATION FACILITIES
 - 4" DENBUR TURBO-METER



LEGEND

- 1" WATER LINE
- 1-1/2" WATER LINE
- 2" WATER LINE
- 3" WATER LINE
- 4" WATER LINE
- 6" WATER LINE
- 8" WATER LINE
- 10" WATER LINE
- 12" WATER LINE
- WET WATER
- DRY WATER
- GATE VALVE
- PLUG
- LINE SIZE CHANGE
- FLUSH VALVE
- FIRE HYDRANT
- BLOW-OFF AIR VALVE
- WELL SITE
- BURIED TRACER WIRE

WESTMINSTER SPECIAL UTILITY DISTRICT SYSTEM MAP MAY 2013

